

Water Test Results

Strait Regional Centre for Education - UPDATE - 2023 September

School Name	Location	Sample ID	Date	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Remediation Plan
Antigonish Education Centre	Fountain 1-Main Entrance	ACO11310	2019-10-20	<0.0005	Passed	0.0150	Passed	
Antigonish Education Centre	Fountain 2-Grade 1-2 Wing	ACO11311	2019-10-20	<0.0005	Passed	0.0360	Passed	
Antigonish Education Centre	Fountain 3-Pre-Primary	ACO11312	2019-10-20	<0.0005	Passed	0.0210	Passed	
Antigonish Education Centre	Fountain 4-by stairwell-2nd floor	ACO11313	2019-10-20	0.0007	Passed	0.0430	Passed	
Antigonish Education Centre	Fountain 5-Wing 3 on 2nd floor	ACO11314	2019-10-20	<0.0005	Passed	0.0180	Passed	
Antigonish Education Centre	Fountain 6-Wing 4 - on 2d floor	ACO11315	2019-10-20	<0.0005	Passed	0.0570	Passed	
Antigonish Education Centre	Food Prep 1-2nd floor-YSF-Rm 2108	ACO11316	2019-10-20	<0.0005	Passed	0.0190	Passed	
Antigonish Education Centre	Food Prep 2-Rm 1005-next to door	ACO11317	2019-10-20	<0.0005	Passed	0.0180	Passed	
Antigonish Education Centre	Food Prep 3-Rm 1005-back corner	ACO11318	2019-10-20	0.0006	Passed	0.0120	Passed	
Antigonish Education Centre	Food Prep 4-Rm 1113-Staff Room	ACO11319	2019-10-20	<0.0005	Passed	0.0180	Passed	
Antigonish Education Centre	Food Prep 5-Rm 1311-Pre-primary	ACO11320	2019-10-20	<0.0005	Passed	0.0200	Passed	
Antigonish Education Centre	Food Prep 6-Rm 1317-Pre-primary	ACO11321	2019-10-20	<0.0005	Passed	0.0170	Passed	
Antigonish Education Centre	Food Prep 7-Rm 1318-Pre-primary	ACO11322	2019-10-20	<0.0005	Passed	0.0200	Passed	
Antigonish Education Centre	Food Prep 8-Rm 1319-Pre-primary	ACO11323	2019-10-20	<0.0005	Passed	0.0410	Passed	
Bayview Education Centre	Fountain 1 - Nearest to Building Entrance	ACO11448	2019-10-19	<0.0005	Passed	0.2500	Passed	
Bayview Education Centre	Fountain 2 - 1st Floor	ACO11449	2019-10-19	<0.0005	Passed	0.1100	Passed	
Bayview Education Centre	Fountain 3 - 2nd Floor	ACO11450	2019-10-19	<0.0005	Passed	0.1700	Passed	
Bayview Education Centre	Fountain 4 - 2nd Floor	ACO11451	2019-10-19	<0.0005	Passed	0.1600	Passed	
Bayview Education Centre	Food Prep 1 - Cafeteria/Kitchen Room 1302 (double sink)	ACO11452	2019-10-19	0.0046	Passed	0.2400	Passed	
Bayview Education Centre	Food Prep 2 - Cafeteria/Kitchen Room 1302 (dish rinsing sink)	BEC-001-PW20-KS1-L1	2020-05-27	0.0009	Passed	0.0460	Passed	
Bayview Education Centre	Food Prep 3 - Cafeteria/Kitchen Room 1302 (hand washing sink)	ACO11454	2019-10-19	0.0032	Passed	0.1500	Passed	
Bayview Education Centre	Food Prep 4 - Staff Lounge	ACO11455	2019-10-19	<0.0005	Passed	0.1200	Passed	
Bayview Education Centre	Food Prep 5 - Daycare Pre Primary	ACO11456	2019-10-19	0.0012	Passed	0.2000	Passed	
Bayview Education Centre	Food Prep 6 - YSF	ACO11457	2019-10-19	0.0016	Passed	0.1100	Passed	
Bayview Education Centre	Food Prep 7 - FST Room 2108 - back counter sink-right side	BEC-001-PW20-KS1-L1	2020-06-27	0.0040	Passed	0.5900	Passed	
Bayview Education Centre	Food Prep 8 - FST Room 2108 - back counter sink-left side	BEC-003-PW20-KS1-L1	2020-05-20	0.0040	Passed	0.5600	Passed	
Bayview Education Centre	Food Prep 9 - FST Room 2108 - work station near window	ACO12471	2021-01-18	<0.0005	Passed	0.6400	Passed	
Bayview Education Centre	Food Prep 10 - FST Room 2108 - work station near door	ACO12472	2021-01-18	<0.0005	Passed	0.2700	Passed	
Bayview Education Centre	Fountain 5 - Gym Fountain	ACO11668	2019-10-19	<0.0005	Passed	0.2900	Passed	
Cape Breton Highlands Education Centre/Academy	Fountain 1 - Next to Pre-Primary room 1203	ACO11458	2019-10-26	<0.0005	Passed	0.0890	Passed	
Cape Breton Highlands Education Centre/Academy	Fountain 2 - Down the Hall From Teachers Lounge	ACO11459	2019-10-26	<0.0005	Passed	0.0190	Passed	
Cape Breton Highlands Education Centre/Academy	Fountain 3 - Gym Hallway 1501	ACO11460	2019-10-26	0.0021	Passed	0.0280	Passed	
Cape Breton Highlands Education Centre/Academy	Fountain 4 - Before Family Studies	ACO11461	2019-10-26	<0.0005	Passed	0.0710	Passed	
Cape Breton Highlands Education Centre/Academy	Fountain 5 - End of Hall Road Side	CBHA-001-PW20-FN2	2020-05-27	0.0011	Passed	0.1500	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 1 - Cafeteria Kitchen Handwashing Sink	ACO11463	2019-10-26	0.0020	Passed	0.1700	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 2 - Cafeteria Kitchen Dish Rinse Station	ACO11464	2019-10-26	0.0025	Passed	0.1200	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 3 - Cafeteria Kitchen next to toaster	CBHA-001-PW20-KS1-L1	2020-10-21	0.0009	Passed	0.1100	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 4 - YSF room 1202	ACO11466	2019-10-26	0.0031	Passed	0.0600	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 5 - Pre-Primary	ACO11467	2019-10-26	0.0012	Passed	0.0820	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 6 - Staff Lunchroom	ACO11468	2019-10-26	0.0005	Passed	0.0430	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 7 - Family Studies - 1st sink against the wall	ACO11469	2019-10-26	0.0019	Passed	0.1500	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 8 - Family Studies - 2nd sink against wall	ACO11470	2019-10-26	0.0020	Passed	0.1100	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 9 - Family Studies - Island Sink hallway side	ACO11471	2019-10-26	0.0018	Passed	0.1100	Passed	
Cape Breton Highlands Education Centre/Academy	Food Prep 10 - Cafeteria Kitchen island sink wall side	ACO11472	2019-10-26	0.0023	Passed	0.2200	Passed	
Chedabucto Education Centre/ Guysborough Academy	Fountain 1 - across from YSF ROOM 20	ACO11394	2019-10-27	<0.0005	Passed	1.8000	Passed	
Chedabucto Education Centre/ Guysborough Academy	Fountain 2 - outside of Gr. 2 & 3 classrooms	ACO11395	2019-10-27	0.0005	Passed	0.8500	Passed	
Chedabucto Education Centre/ Guysborough Academy	Fountain 3 - next to room 126	ACO11396	2019-10-27	<0.0005	Passed	1.9000	Passed	

School Name	Location	Sample ID	Date	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Remediation Plan
Chedabucto Education Centre/ Guysborough Academy	Fountain 4 - across from MultiMedia Room	ACO11397	2019-10-27	<0.0005	Passed	1.5000	Passed	
Chedabucto Education Centre/ Guysborough Academy	Fountain 5 - across from Rec. Office	ACO11398	2019-10-27	<0.0005	Passed	0.3900	Passed	
Chedabucto Education Centre/ Guysborough Academy	Food Prep 1-YSF room 132-by window	ACO11399	2019-10-27	0.0005	Passed	0.3300	Passed	
Chedabucto Education Centre/ Guysborough Academy	Food Prep 2-YSF room 132-3rd in the room	ACO11400	2019-10-27	<0.0005	Passed	2.0000	Passed	
Chedabucto Education Centre/ Guysborough Academy	Food Prep 3-YSF room 132-2nd in the room	ACO11401	2019-10-27	0.0015	Passed	0.3600	Passed	
Chedabucto Education Centre/ Guysborough Academy	Food Prep 4-YSF room 132-1st in the room	ACO11402	2019-10-27	0.0006	Passed	1.9000	Passed	
Chedabucto Education Centre/ Guysborough Academy	Food Prep 5-Cafeteria Kitchen	ACO11403	2019-10-27	0.0009	Passed	0.0970	Passed	
Chedabucto Education Centre/ Guysborough Academy	Food Prep 6 - Room 25 Staff Room	ACO11613	2019-10-27	<0.0005	Passed	0.1200	Passed	
Chedabucto Education Centre/ Guysborough Academy	Food Prep 7 - YSF Room 113 Kitchen Tap	ACO11614	2018-20-27	<0.0005	Passed	0.3100	Passed	
Dalbrae Academy	Fountain 1 - outside of staff room	ACO11473	2019-11-02	<0.0005	Passed	0.0940	Passed	
Dalbrae Academy	Fountain 2 - Gymnasium	ACO11474	2019-11-02	<0.0005	Passed	0.0970	Passed	
Dalbrae Academy	Fountain 3 - Blue Wing	ACO11475	2019-11-02	<0.0005	Passed	0.1200	Passed	
Dalbrae Academy	Fountain 4 - Green Wing	ACO11476	2019-11-02	<0.0005	Passed	0.0750	Passed	
Dalbrae Academy	Fountain 5 - Red Wing	ACO11477	2019-11-02	<0.0005	Passed	0.1300	Passed	
Dalbrae Academy	Food Prep 1-Admin. Room Sink	ACO11478	2019-11-02	0.0016	Passed	0.1500	Passed	
Dalbrae Academy	Food Prep 2-Staff Room	ACO11479	2019-11-02	<0.0005	Passed	0.0740	Passed	
Dalbrae Academy	Food Prep 3 - Cafeteria Kitchen -sink against wall	ACO11533	2019-11-02	<0.0005	Passed	0.0720	Passed	
Dalbrae Academy	Food Prep 4-Cafeteria Kitchen - sink center island	ACO11657	2019-11-02	0.0007	Passed	0.1100	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 1 - Staff Room - Refill Station	ACO11327	2019-10-20	<0.0005	Passed	0.0050	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 1 - Staff Room - Refill Station	ACO11327	2019-10-20	0.0075	Exceeds Limit	0.3600	Passed	Removed from service
Dr. John Hugh Gillis Regional High School	Fountain 2 - Wing 4 by Music Room 2123	ACO11328	2019-10-20	0.0000	Passed	0.1100	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 2 - Wing 4 by Music Room 2123	ACO11328	2019-10-20	0.0041	Passed	0.3100	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 3 - Refill Station - next to room 2014	ACO11329	2019-10-20	<0.0005	Passed	0.0980	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 3 - Refill Station - next to room 2014	ACO11329	2019-10-20	0.0010	Passed	0.1800	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 4 - Grade 12 area next to washrooms	ACO11330	2019-10-20	<0.0005	Passed	0.1800	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 4 - Grade 12 area next to washrooms	ACO11330	2019-10-20	0.0010	Passed	0.2800	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 5 - Gym -next to boys change room	ACO11331	2019-10-20	0.0006	Passed	0.1100	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 5 - Gym -next to boys change room	ACO11331	2019-10-20	0.0007	Passed	0.2300	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 6 - Gym - next to girls change room	ACO11332	2019-10-20	<0.0005	Passed	0.0970	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 6 - Gym - next to girls change room	ACO11332	2019-10-20	0.0011	Passed	0.1700	Passed	
Dr. John Hugh Gillis Regional High School	Fountain 7 - Grade 10 area next to washrooms	ACO11333	2019-10-20	<0.0005	Passed	0.0520	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 1 - Community Living	ACO11334	2019-10-20	<0.0005	Passed	0.0620	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 5 - Second Floor Cooking Lab - individual sink 2103	ACO11338	2019-10-20	0.0047	Passed	0.1300	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 6 - Second Floor Cooking Lab - first on left 2103	ACO11339	2019-10-20	0.0019	Passed	0.1200	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 7 - Second Floor Cooking Lab - second on left 2103	ACO11340	2019-10-20	0.0006	Passed	0.1000	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 8 - Second Floor Cooking Lab - second on right 2103	ACO11341	2019-10-20	0.0009	Passed	0.1500	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 9 - Second Floor Cooking Lab - first on right 2103	ACO11342	2019-10-20	0.0006	Passed	0.1400	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 10 - Cafeteria Kitchen small room	ACO11343	2019-10-20	<0.0005	Passed	0.2300	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 11 - Cafeteria Kitchen large room	ACO11344	2019-10-20	<0.0005	Passed	0.0760	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 4 - Second Floor Kitchen - Dishwashing Stn 2104	ACO11539	2020-02-28	0.0740	Exceeds Limit	0.2900	Passed	Removed from service
Dr. John Hugh Gillis Regional High School	Food Prep 3 - Second Floor Kitchen room 2104	DJHG-006-PW20-KS2	2020-10-22	0.0004	Passed	0.3200	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 3 - Second Floor Kitchen room 2104	DJHG-PW20-006-KS2	2020-01-21	0.0014	Passed	0.2700	Passed	
Dr. John Hugh Gillis Regional High School	Food Prep 2 - Second Floor Old Office # 2040	DJHG-PW20-005-KS2	2020-01-21	0.0048	Passed	0.0090	Passed	
Dr. John Hugh Gillis Regional High School	Gym Female Washroom Tap 1	ACO11570	2019-11-03	0.0016	Passed	0.0430	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Gym Male Washroom Tap 1	ACO11571	2019-11-03	0.0018	Passed	0.0680	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Locker Room 1 - Washroom Tap 2	ACO11572	2019-11-03	0.0015	Passed	0.1400	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Locker Room 1 - Washroom Tap 1	ACO11573	2019-11-03	0.0020	Passed	0.1100	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Locker Room 2 - Washroom Tap	ACO11574	2019-11-03	0.0025	Passed	0.2300	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Locker Room 3 - Washroom Tap 1	ACO11575	2019-11-03	<0.0005	Passed	0.0880	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Locker Room 3 - Washroom Tap 2	ACO11576	2019-11-03	0.0009	Passed	0.1800	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Locker Room 4 - Washroom Tap	ACO11577	2019-11-03	0.0022	Passed	0.2000	Passed	Non-potable source - signage posted

School Name	Location	Sample ID	Date	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Remediation Plan
Dr. John Hugh Gillis Regional High School	Janitors Room Tap - Main Hallway	ACO11578	2019-11-03	0.0000	Passed	0.0980	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Main Hallway - Tap 3	ACO11581	2019-11-03	0.0032	Passed	0.2200	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 10 Hallway - Tap 1	ACO11582	2019-11-03	0.0010	Passed	0.0820	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Main Hallway - Tap 2	ACO11583	2019-11-03	0.0008	Passed	0.1000	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 9 Hallway - Tap 2	ACO11584	2019-11-03	0.0024	Passed	0.2000	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Auto Shop Tap - 1st floor	ACO11585	2019-11-03	<0.0005	Passed	0.1300	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Wood Shop Tap	ACO11586	2019-11-03	0.0230	Exceeds Limit	0.0610	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boiler Room Tap - Auto Shop Hallway	ACO11587	2019-11-03	0.0310	Exceeds Limit	1.7000	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Community Living Washroom - Auto Shop Hallway - Tap 1	ACO11588	2019-11-03	0.0017	Passed	0.1200	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Community Living Washroom - Auto Shop Hallway - Tap 2	ACO11589	2019-11-03	<0.0005	Passed	0.1100	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 10 Hallway - Tap 1	ACO11590	2019-11-03	0.0025	Passed	0.1900	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Gender Neutral Washroom Tap	ACO11591	2019-11-03	<0.0005	Passed	0.1200	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 9 Hallway - Tap 3	ACO11592	2019-11-03	0.0007	Passed	0.2300	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Auto Shop Hallway - Tap 1	ACO11593	2019-11-03	0.0006	Passed	0.0390	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Auto Shop Hallway - Tap 2	ACO11594	2019-11-03	0.0011	Passed	0.0720	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 10 Hallway - Tap 2	ACO11595	2019-11-03	0.0047	Passed	0.2200	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Janitors Room Tap - Auto Shop Hallway	ACO11596	2019-11-03	0.0016	Passed	0.0920	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Trades Room Tap	ACO11597	2019-11-03	0.0017	Passed	0.0690	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 9 Hallway - Tap 1	ACO11598	2019-11-03	0.0010	Passed	0.1800	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 9 Hallway - Tap 2	ACO11599	2019-11-03	0.0010	Passed	0.2800	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Auto Shop Hallway - Tap 3	ACO11600	2019-11-03	0.0010	Passed	0.0740	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 10 Hallway - Tap 2	ACO11601	2019-11-03	0.0010	Passed	0.0940	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 9 Hallway - Tap 1	ACO11602	2019-11-03	0.0033	Passed	0.2500	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 10 Hallway - Tap 3	ACO11618	2019-11-03	0.0025	Passed	0.2600	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Janitors Washroom Tap - Grade 9 Hallway	ACO11619	2019-11-03	0.0023	Passed	0.0430	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Trades Building Tap - Back Exterior of School	ACO11620	2019-11-03	0.0011	Passed	0.1100	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Cafeteria Kitchen - Room 2100 - Handwashing Sink	ACO11621	2019-11-03	0.0007	Passed	0.1900	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Main Office Handwashing Sink	ACO11622	2019-11-03	0.0010	Passed	0.2300	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Classroom 2102 Tap - Sewing Room	DJHG-PW20-001-K51	2019-11-03	<0.0005	Passed	0.1200	Passed	
Dr. John Hugh Gillis Regional High School	Classroom 2100 Tap - Special Needs	ACO11624	2019-11-03	0.0010	Passed	0.2200	Passed	
Dr. John Hugh Gillis Regional High School	Classroom 2198 Tap	ACO11625	2019-11-03	0.0011	Passed	0.1400	Passed	
Dr. John Hugh Gillis Regional High School	Girls Washroom - Main Hallway 2nd Floor - Tap 1	ACO11626	2020-02-18	0.0050	Passed	0.2200	Passed	
Dr. John Hugh Gillis Regional High School	Girls Washroom - Main Hallway 2nd Floor - Tap 2	ACO11627	2019-11-03	0.0037	Passed	0.1700	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Main Hallway 2nd Floor - Tap 3	ACO11628	2019-11-03	0.0029	Passed	0.3100	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Music Room 2123 Tap	ACO11629	2019-11-03	<0.0005	Passed	0.2000	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Staff Washroom - Main Hallway 2nd Floor	ACO11630	2019-11-03	0.0020	Passed	0.1300	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Main Hallway 2nd Floor - Tap 1	ACO11631	2019-11-03	0.0021	Passed	0.1300	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Main Hallway - Tap 1	ACO11632	2019-11-03	0.0021	Passed	0.1600	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Main Hallway 2nd Floor - Tap 3	ACO11633	2019-11-03	0.0011	Passed	0.2000	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Classroom 2191 Tap	ACO11634	2019-11-03	0.0023	Passed	0.2200	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Art Room 2084 - Tap 1	ACO11636	2019-11-03	0.0005	Passed	0.1600	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Art Room 2084 - Tap 2	ACO11637	2019-11-03	0.0008	Passed	0.1200	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Art Room 2085 - Tap 1	DJHG-PW20-005-US1	2020-02-18	0.0015	Passed	3.8000	Exceeds Limit	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Art Room 2085 - Tap 2	ACO11639	2019-11-03	0.0014	Passed	0.1800	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 9 Hallway - Tap 3	ACO11641	2019-11-03	0.0030	Passed	0.2000	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 10 Hallway - Tap 3	ACO11642	2019-11-03	0.0022	Passed	0.1500	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 1	DJHG-PW20-003-B52	2020-02-18	0.0091	Passed	0.2000	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 2	ACO11644	2019-11-03	0.0027	Passed	0.1700	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 11 Hallway 2nd Floor - Tap 3	ACO11645	2019-11-03	0.0016	Passed	0.2000	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Janitors Room Tap - Grade 11 Hallway 2nd Floor	ACO11646	2019-11-03	0.0005	Passed	0.1100	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Guidance Office Tap - Grade 11 Hallway 2nd Floor	ACO11647	2019-11-03	<0.0005	Passed	0.2500	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Doctor's Tap - Grade 12 Hallway 2nd Floor	ACO11648	2019-11-03	0.0085	Exceeds Limit	0.5600	Passed	Non-potable source - signage posted

School Name	Location	Sample ID	Date	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Remediation Plan
Dr. John Hugh Gillis Regional High School	Dr Office Washroom Tap	ACO11649	2019-11-03	0.0007	Passed	0.0460	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 11 Hallway 2nd Floor - Tap 1	ACO11650	2019-11-03	0.0015	Passed	0.1600	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 12 Hallway 2nd Floor - Tap 2	ACO11651	2019-11-03	0.0040	Passed	0.3400	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Boys Washroom - Grade 12 Hallway 2nd Floor - Tap 3	ACO11652	2019-11-03	0.0026	Passed	0.2200	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 1	ACO11653	2019-11-03	0.0035	Passed	0.3400	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 2	ACO11654	2019-11-03	0.0030	Exceeds Limit	0.3600	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Girls Washroom - Grade 12 Hallway 2nd Floor - Tap 3	ACO11655	2019-11-03	0.0041	Passed	0.3100	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Janitor Room Grade 12 Hallway	ACO11656	2019-11-03	0.0013	Passed	0.0570	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	School Plus Classroom - Female Washroom	ACO11658	2019-11-03	0.0043	Passed	0.1800	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	School Plus Classroom - Male Washroom	ACO11659	2019-11-03	0.0046	Passed	0.1500	Passed	Non-potable source - signage posted
Dr. John Hugh Gillis Regional High School	Staff Washroom - 2nd floor by Music Room	ACO11660	2020-02-18	0.0008	Passed	0.0960	Passed	Non-potable source - signage posted
East Antigonish Education Centre/Academy	Food Prep 1-2nd floor-YSF-room # 2108	ACO11316	2019-10-26	<0.0005	Passed	0.0190	Passed	
East Antigonish Education Centre/Academy	Food Prep 2-Rm 1005-closest to door	ACO11317	2019-10-26	<0.0005	Passed	0.0180	Passed	
East Antigonish Education Centre/Academy	Food Prep-3-Rm 1005-back corner	ACO11318	2019-10-26	0.0033	Passed	0.0120	Passed	
East Antigonish Education Centre/Academy	Food Prep 4-Rm 1113-Staff Room	ACO11319	2019-10-26	0.0021	Passed	0.0180	Passed	
East Antigonish Education Centre/Academy	Food Prep 5-Room 1311-Pre-primary	ACO11320	2019-10-26	<0.0005	Passed	0.0200	Passed	
East Antigonish Education Centre/Academy	Food Prep 6-Room 1317-Pre-primary	ACO11321	2019-10-26	<0.0005	Passed	0.0170	Passed	
East Antigonish Education Centre/Academy	Food Prep 7-Room 1318-Pre-primary	ACO11322	2019-10-26	<0.0005	Passed	0.0200	Passed	
East Antigonish Education Centre/Academy	Food Prep 8-Room 1319-Pre-primary	ACO11323	2019-10-26	0.0007	Passed	0.0410	Passed	
East Antigonish Education Centre/Academy	Fountain 1 - Early Years Hallway - next to Grade 4	ACO11345	2019-10-26	<0.0005	Passed	0.1000	Passed	
East Antigonish Education Centre/Academy	Fountain 2 - Elementary Wing	ACO11346	2019-10-26	<0.0005	Passed	0.1100	Passed	
East Antigonish Education Centre/Academy	Fountain 3 - Bottle Refill Str. Gym hallway	ACO11347	2019-10-26	<0.0005	Passed	0.1000	Passed	
East Antigonish Education Centre/Academy	Fountain 4 - 2nd floor - Sr. Wing 10-12	ACO11348	2019-10-26	<0.0005	Passed	0.1100	Passed	
East Antigonish Education Centre/Academy	Fountain 5 - South Wing - Grade 5 - 6	ACO11349	2019-10-26	<0.0005	Passed	0.1500	Passed	
East Antigonish Education Centre/Academy	Fountain 6 - North Wing	ACO11350	2019-10-26	<0.0005	Passed	0.2000	Passed	
East Antigonish Education Centre/Academy	Food Prep 9 - Family Studies - 2nd sink to the right	ACO11606	2019-10-26	<0.0005	Passed	0.1100	Passed	
East Antigonish Education Centre/Academy	Food Prep 10 - Family Studies - 3rd sink to the right	ACO11607	2019-10-26	0.0006	Passed	0.0770	Passed	
East Antigonish Education Centre/Academy	Food Prep 11 - Family Studies - 4th sink to the right	ACO11608	2019-10-26	0.0008	Passed	0.1600	Passed	
East Antigonish Education Centre/Academy	Food Prep 12 - Family Studies - sink against the wall	ACO11609	2019-10-26	0.0007	Passed	0.1700	Passed	
East Richmond Education Centre	Fountain 1 - Wing 1 - by room 149	ACO11425	2019-10-19	<0.0005	Passed	0.0570	Passed	
East Richmond Education Centre	Food Prep 1 - Cafeteria Kitchen Sink by Storage Room	ACO11426	2019-10-19	0.0006	Passed	0.0900	Passed	
East Richmond Education Centre	Food Prep 2 - Cafeteria Kitchen - Prewash Station	ERES-003-PW20-KS1	2020-01-21	0.0020	Passed	0.2200	Passed	
East Richmond Education Centre	Food Prep 3 - Cafeteria Kitchen sink next to entry	ERES-004-PW20-KS2	2020-01-21	0.0041	Passed	0.1900	Passed	
East Richmond Education Centre	Food Prep 4 - Cafeteria Kitchen - handwashing	ACO11429	2019-10-19	0.0028	Passed	0.1400	Passed	
East Richmond Education Centre	Food Prep 5 - Family Studies - by window	ACO11430	2019-10-19	<0.0005	Passed	0.1200	Passed	
East Richmond Education Centre	Food Prep 6 - Family Studies - by door entry	ACO11431	2019-10-19	<0.0005	Passed	0.1700	Passed	
East Richmond Education Centre	Food Prep 7 - Family Studies - centre sinks	ACO11432	2019-10-19	0.0007	Passed	0.1200	Passed	
East Richmond Education Centre	Food Prep 8 - Day Care Tap 1	ACO11662	2019-11-14	0.0007	Passed	0.1300	Passed	
East Richmond Education Centre	Food Prep 9 - Day Care Tap 2	ACO11663	2019-11-19	<0.0005	Passed	0.0810	Passed	
East Richmond Education Centre	Food Prep 11 - Pre Primary Tap	ERES-PW20-001-KS1	2020-10-23	0.0018	Passed	0.7600	Passed	
East Richmond Education Centre	Fountain 2 - Wing 1 - by room 165	ACO11665	2019-11-14	<0.0005	Passed	0.2700	Passed	
East Richmond Education Centre	Fountain 3 - Wing 2 - by room 178	ERES-002-PW20-FN1	2020-01-21	<0.0005	Passed	0.2700	Passed	
East Richmond Education Centre	Fountain 4 - Gym	ACO11667	2019-11-14	0.0009	Passed	0.3100	Passed	
East Richmond Education Centre	Food Prep 10 - Day Care Small Sink	ACO11671	2019-11-14	0.0007	Passed	0.1300	Passed	
Fanning Education Centre/ Canso Academy	Fountain 1 - Main Entrance - Bottle Refill Station	ACO11404	2019-10-27	<0.0005	Passed	0.7800	Passed	
Fanning Education Centre/ Canso Academy	Fountain 2 - By room 123	ACO11405	2019-10-27	<0.0005	Passed	0.3500	Passed	
Fanning Education Centre/ Canso Academy	Fountain 3 - By room 137	ACO11406	2019-10-27	<0.0005	Passed	0.5100	Passed	
Fanning Education Centre/ Canso Academy	Fountain 4 - Wing 7-9	ACO11407	2019-10-27	<0.0005	Passed	0.7800	Passed	
Fanning Education Centre/ Canso Academy	Fountain 5 - Wing 10-12	ACO11408	2019-10-27	<0.0005	Passed	0.3500	Passed	
Fanning Education Centre/ Canso Academy	Food Prep 1 - Cafeteria Room 151 - double sink	ACO11409	2019-10-27	0.0005	Passed	1.8000	Passed	
Fanning Education Centre/ Canso Academy	Food Prep 2 - Cafeteria Kitchen room 117 - single sink	ACO11410	2019-10-27	0.0028	Passed	1.4000	Passed	
Fanning Education Centre/ Canso Academy	Food Prep 3 - Cafeteria Kitchen room 117 - double sink	ACO11411	2019-10-27	<0.0005	Passed	1.9000	Passed	

School Name	Location	Sample ID	Date	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Remediation Plan
Fanning Education Centre/ Canso Academy	Food Prep 4 - Multi-purpose room 114 - single sink	ACO11412	2019-10-27	0.0015	Passed	0.4100	Passed	
Fanning Education Centre/ Canso Academy	Food Prep 5 - Multi-purpose room 114 - island sink	ACO11413	2019-10-27	0.0007	Passed	0.6000	Passed	
Fanning Education Centre/ Canso Academy	Food Prep 6 - Staff Room 102	ACO11610	2019-10-27	<0.0005	Passed	0.2800	Passed	
Fanning Education Centre/ Canso Academy	Food Prep 7 - Cafeteria Room 113 Tap	ACO11611	2019-10-27	<0.0005	Passed	1.0000	Passed	
Fanning Education Centre/ Canso Academy	Food Prep 8 - Janitors Staff Room 151	ACO11612	2019-10-27	<0.0005	Passed	0.5100	Passed	
Felix Marchand Education Centre	Food Prep 1 - Staff Lunchroom	ACO11433	2019-10-19	0.0032	Passed	0.0260	Passed	
H.M. MacDonald Elementary School	Fountain 1 - Next to Girls washroom	ACO11356	2019-10-26	<0.0005	Passed	0.0870	Passed	
H.M. MacDonald Elementary School	Fountain 2 - Next to Janitors Storage room	ACO11357	2019-10-26	0.0031	Passed	0.0830	Passed	
H.M. MacDonald Elementary School	Food Prep 1-Lunch Room	ACO11358	2019-10-26	0.0025	Passed	0.0660	Passed	
Inverness Education Centre/Academy	Fountain 1 - Entrance	ACO11480	2019-10-19	<0.0005	Passed	0.0660	Passed	
Inverness Education Centre/Academy	Fountain 2 - Back of School	ACO11481	2019-10-26	<0.0005	Passed	0.0300	Passed	
Inverness Education Centre/Academy	Fountain 3 - Upstairs	ACO11482	2019-10-26	<0.0005	Passed	0.1600	Passed	
Inverness Education Centre/Academy	Food Prep 1 - Staff Lounge	ACO11483	2019-10-26	0.0001	Passed	0.0620	Passed	
Inverness Education Centre/Academy	Food Prep 2 - FST Class	ACO11484	2019-10-26	0.0004	Passed	0.0870	Passed	
Pleasant Bay School	Food Prep 1 - Lunch Room	ACO11485	2019-10-26	0.0019	Passed	0.0690	Passed	
Pleasant Bay School	Sample Location 2 - Water Source	PBS-001-PW20-BR1	2020-07-21	0.0005	Exceeds Limit	4.1000	Exceeds Limit	Non-potable source - signage posted
Pleasant Bay School	Sample Location 3 - Boys Washroom Upstairs	ACO11535	2019-10-26	0.0017	Passed	0.2400	Passed	Non-potable source - signage posted
Pleasant Bay School	Sample Location 4 - Girls Washroom Upstairs	ACO11536	2019-10-26	0.0022	Passed	0.1700	Passed	Non-potable source - signage posted
Pleasant Bay School	Sample Location 5 - Washroom Downstairs	PBS-002-PW20-BR1	2020-07-21	0.0006	Passed	0.1500	Passed	Non-potable source - signage posted
Richmond Education Centre/Academy	Fountain 1 - Main Floor Near Room 1800	ACO11434	2019-10-19	<0.0005	Passed	0.2900	Passed	
Richmond Education Centre/Academy	Fountain 2 - Near Room 1000	ACO11435	2019-10-19	0.0005	Passed	0.3000	Passed	
Richmond Education Centre/Academy	Fountain 3 - Near Room 1101	ACO11436	2019-10-19	<0.0005	Passed	0.4700	Passed	
Richmond Education Centre/Academy	Fountain 4 - Second Floor Away From Cooking Lab	ACO11437	2019-10-19	<0.0005	Passed	0.4600	Passed	
Richmond Education Centre/Academy	Fountain 5 - 2nd Floor Near Cooking Lab	ACO11438	2019-10-19	<0.0005	Passed	0.4600	Passed	
Richmond Education Centre/Academy	Food Prep 1 - Cafeteria Kitchen-main sink	ACO11439	2019-10-19	0.0013	Passed	0.2900	Passed	
Richmond Education Centre/Academy	Food Prep 2 - Cafeteria Kitchen-food prep	ACO11440	2019-10-19	0.0015	Passed	0.2000	Passed	
Richmond Education Centre/Academy	Food Prep 3 - Cafeteria Kitchen-by entry door	ACO11441	2019-10-19	<0.0005	Passed	0.1700	Passed	
Richmond Education Centre/Academy	Food Prep 4 - YSF Cooking Lab - room 1807	ACO11442	2019-10-19	0.0014	Passed	0.2600	Passed	
Richmond Education Centre/Academy	Food Prep 5 - YSF Cooking Lab - room 1807	ACO11443	2019-10-19	<0.0005	Passed	0.1600	Passed	
Richmond Education Centre/Academy	Food Prep 6 - Teacher Staff Room 1608	ACO11444	2019-10-19	<0.0005	Passed	0.2800	Passed	
Richmond Education Centre/Academy	Food Prep 7 - 2nd Floor Cooking Lab Room 2013 - 1st Wall Sink	ACO11445	2019-10-19	0.0015	Passed	0.1200	Passed	
Richmond Education Centre/Academy	Food Prep 8 - 2nd Floor Cooking Lab Room 2013 - 2nd Wall Sink	ACO11446	2019-10-19	0.0012	Passed	0.2300	Passed	
Richmond Education Centre/Academy	Food Prep 9 - 2nd Floor Cooking Lab Room 2013 - Island Sink	ACO11447	2019-10-19	0.0009	Passed	0.2900	Passed	
St. Andrew Junior School	Fountain 1 - Corridor 011 by elevator	ACO11377	2019-10-26	<0.0005	Passed	0.0500	Passed	
St. Andrew Junior School	Fountain 2 - Corridor 011 by Janitor's Closet	ACO11378	2019-10-26	<0.0005	Passed	0.0540	Passed	
St. Andrew Junior School	Fountain 3 - Corridor 061 outside of Tech Ed	ACO11379	2019-10-26	<0.0005	Passed	0.2100	Passed	
St. Andrew Junior School	Fountain 4 - Outside Science Room 228	ACO11381	2019-10-26	0.0013	Passed	0.0650	Passed	
St. Andrew Junior School	Food Prep 1 - Nutrition Room # 207 separate sink	SAJS-001-PW20-KS1	2020-01-18	0.0021	Passed	0.0870	Passed	
St. Andrew Junior School	Food Prep 2 - Nutrition Room # 207 1st on the left	SAJS-003-PW20-KS2	2020-05-20	0.0021	Passed	0.0490	Passed	
St. Andrew Junior School	Food Prep 3 - Nutrition Room # 207 - 1st on the right	SAJS-004-PW20-KS2	2020-01-28	0.0025	Passed	0.0510	Passed	
St. Andrew Junior School	Food Prep 4 - Nutrition Room # 207 2nd on the right	SAJS-005-PW20-KS2	2020-05-20	0.0025	Passed	0.0520	Passed	
St. Andrew Junior School	Food Prep 5 - Nutrition Room # 207 2nd on the left	SAJS-006-PW20-KS2	2020-05-20	0.0021	Passed	0.0350	Passed	
St. Andrew Junior School	Food Prep 6 - YSF Room # 218	ACO11388	2019-10-26	0.0012	Passed	0.2900	Passed	
St. Andrew Junior School	Food Prep 7 - Special Needs Room # 233	SAJS-006-PW20-KS2	2020-11-18	<0.0005	Passed	0.0530	Passed	
St. Andrew Junior School	Food Prep 8 - YSF Room # 101	ACO11390	2019-10-26	0.0025	Passed	0.1700	Passed	
St. Andrew Junior School	Food Prep 9 - Class Room # 116	ACO11391	2019-10-26	0.0007	Passed	0.0850	Passed	
St. Andrew Junior School	Food Prep 10 - Cafeteria Kitchen	ACO11392	2019-10-26	0.0007	Passed	0.0360	Passed	
St. Andrews Consolidated School	Fountain 1 - Front Entrance outside room 3	ACO11360	2019-10-26	<0.0005	Passed	0.0220	Passed	
St. Andrews Consolidated School	Fountain 2 - Outside room 152	ACO11361	2019-10-26	0.0035	Passed	0.2900	Passed	Removed from service
St. Andrews Consolidated School	Fountain 3 - Outside room 153	ACO11362	2019-10-26	0.0032	Passed	0.3000	Passed	
St. Andrews Consolidated School	Fountain 4 - Hallway 111	ACO11363	2019-10-26	<0.0005	Passed	0.1100	Passed	

School Name	Location	Sample ID	Date	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Remediation Plan
St. Andrews Consolidated School	Fountain 5 - Room 113 Grade Primary porcelain fountain	SACE-004-PW20-FN1-L1	2020-01-28	0.0040	Passed	0.4300	Passed	Removed from service
St. Andrews Consolidated School	Fountain 6 - Room 101 Grade primary porcelain fountain	ACO11365	2019-10-26	0.0021	Passed	0.3100	Passed	Removed from service
St. Andrews Consolidated School	Food Prep 1 - Room 128 - Cafeteria Kitchen - centre sink	ACO11366	2019-10-26	0.0009	Passed	0.0480	Passed	
St. Andrews Consolidated School	Food Prep 2 - Room 128 - Cafeteria Kitchen - handwashing	ACO11367	2019-10-26	0.0016	Passed	0.0420	Passed	
St. Andrews Consolidated School	Food Prep 3 - Room 128 - Cafeteria Kitchen - prep sink	ACO11368	2019-10-26	0.0029	Passed	0.0250	Passed	
St. Andrews Consolidated School	Food Prep 4 - Room 128 - Cafeteria Kitchen - Dishwashing	ACO11369	2019-10-26	0.0005	Passed	0.2500	Passed	
St. Andrews Consolidated School	Food Prep 5 - Room 101 - Primary	ACO11370	2019-10-26	0.0005	Passed	0.0720	Passed	
St. Andrews Consolidated School	Food Prep 6 - Room 113 - Grade Primary	ACO11371	2019-10-26	0.0010	Passed	0.1500	Passed	
St. Andrews Consolidated School	Food Prep 7 - Room 116 - Grade 1 kitchen sink	SACE-003-PW20-KS1-L1	2020-01-28	0.0010	Passed	0.1400	Passed	
St. Andrews Consolidated School	Food Prep 8 - Room 117 - Grade 1 kitchen sink	SACE-002-PW20-KS1-L1	2020-01-28	0.0002	Passed	0.1300	Passed	
St. Andrews Consolidated School	Food Prep 9 - Room 126A - Pre-Primary	ACO11374	2019-10-26	0.0020	Passed	0.0880	Passed	
St. Andrews Consolidated School	Food Prep 10 - Room 127 - Student Services	ACO11375	2019-10-26	0.0026	Passed	0.1400	Passed	
St. Andrews Consolidated School	Food Prep 11 Room 138 - Staff Room	ACO11376	2019-10-26	0.0002	Passed	0.1200	Passed	
St. Mary's Education Centre/Academy	Fountain 1 - Outside of room 168	ACO11415	2019-10-27	<0.0005	Passed	0.0018	Passed	Removed from service
St. Mary's Education Centre/Academy	Fountain 2 - Main Entrance	ACO11416	2019-10-27	<0.0005	Passed	0.1500	Passed	
St. Mary's Education Centre/Academy	Fountain 3 - Main Hall - 2nd floor	ACO11417	2019-10-27	<0.0005	Passed	0.1300	Passed	
St. Mary's Education Centre/Academy	Food Prep 1 - Family Studies - 1st sink - individual	ACO11418	2019-10-27	0.0012	Passed	0.3800	Passed	
St. Mary's Education Centre/Academy	Food Prep 2 - island sink - 1st to the left	ACO11419	2019-10-27	0.0007	Passed	0.0033	Passed	
St. Mary's Education Centre/Academy	Food Prep 3 - island sink - 1st to the right	ACO11420	2019-10-27	<0.0005	Passed	0.0033	Passed	
St. Mary's Education Centre/Academy	Food Prep 4 - island sink - 2nd to the right	ACO11421	2019-10-27	<0.0005	Passed	0.0030	Passed	
St. Mary's Education Centre/Academy	Food Prep 5 - island sink - 2nd to the left	ACO11422	2019-10-27	<0.0005	Passed	0.0034	Passed	
St. Mary's Education Centre/Academy	Food Prep 6 - Staff Room 109	ACO11423	2019-10-27	<0.0005	Passed	0.0045	Passed	
St. Mary's Education Centre/Academy	Food Prep 7 - Cafeteria Kitchen room 113	ACO11424	2019-10-27	0.0030	Passed	0.1100	Passed	
St. Mary's Education Centre/Academy	Food Prep 8 - Room 111 Cafeteria Eating Area - sink	ACO11615		0.0065	Passed	0.1600	Passed	Removed from service
St. Mary's Education Centre/Academy	Food Prep 10 - Room 118 YSF Kitchen Sink	SMEC-PW-20-001-KS1	2019-10-27	0.0028	Passed	0.5100	Passed	
St. Mary's Education Centre/Academy	Food Prep 9 - Room 113 Cafeteria Kitchen Sink	ACO11617	2019-10-27	0.0007	Passed	0.0160	Passed	
Strait Area Education and Recreation Centre	Fountain 1 - In the Gym	ACO11525	2019-10-27	<0.0005	Passed	0.1000	Passed	
Strait Area Education and Recreation Centre	Fountain 2 - By the Library	ACO11487	2019-10-27	<0.0005	Passed	0.0510	Passed	
Strait Area Education and Recreation Centre	Fountain 3 - Next to 3rd Floor Washrooms	ACO11488	2019-10-27	<0.0005	Passed	0.0470	Passed	
Strait Area Education and Recreation Centre	Fountain 4 - 2nd floor hallway	ACO11669	2019-11-14	<0.0005	Passed	0.0590	Passed	
Strait Area Education and Recreation Centre	Food Prep 1 - Food Lab 1st Sink on door side of 1st Island	ACO11526	2019-10-27	0.0018	Passed	0.0380	Passed	
Strait Area Education and Recreation Centre	Food Prep 2 - Food Lab room 252 - against the wall	ACO11527	2019-10-27	0.0013	Passed	0.0370	Passed	
Strait Area Education and Recreation Centre	Food Prep 3 - Cafeteria Kitchen Triple Sink	ACO11528	2019-10-27	<0.0005	Passed	0.0690	Passed	
Strait Area Education and Recreation Centre	Food Prep 4 - Daycare Sink Right of Dishwasher	ACO11529	2019-10-27	<0.0005	Passed	0.1400	Passed	
Strait Area Education and Recreation Centre	Food Prep 5 - YSF Double Sink (Rm 246)	ACO11530	2019-10-27	0.0042	Passed	0.0890	Passed	
Strait Area Education and Recreation Centre	Food Prep 6 - Teachers Staff Lunch Room 208	ACO11494	2019-10-27	0.0015	Passed	0.0950	Passed	
Strait Area Education and Recreation Centre	Food Prep 7 - Cafeteria Kitchen Dish Rinse Station	SAREC-001-PW20-KS1	2020-05-27	0.0047	Passed	0.2500	Passed	
Strait Area Education and Recreation Centre	Food Prep 8 - Teen Health Room 305	ACO11496	2019-10-27	0.0012	Passed	0.5600	Passed	
Strait Area Education and Recreation Centre	Food Prep 9 - Staff room 2nd Floor	ACO11670	2019-11-14	<0.0005	Passed	0.2900	Passed	
Tamarac Education Centre	Fountain 1 - Before YSF Room	ACO11497	2019-10-20	<0.0005	Passed	0.0400	Passed	
Tamarac Education Centre	Fountain 2 - Next to Gym	ACO11498	2019-10-20	<0.0005	Passed	0.0290	Passed	
Tamarac Education Centre	Fountain 3 - Outside Classroom 2017	ACO11499	2019-10-20	<0.0005	Passed	0.0500	Passed	
Tamarac Education Centre	Fountain 4 - Upstairs	ACO11500	2019-10-20	<0.0005	Passed	0.0220	Passed	
Tamarac Education Centre	Fountain 5 - Outside Upstairs Washroom	ACO11501	2019-10-20	<0.0005	Passed	0.0250	Passed	
Tamarac Education Centre	Food Prep 1 - Cafeteria Sink at Doorway	ACO11502	2019-10-20	0.0010	Passed	0.0280	Passed	
Tamarac Education Centre	Food Prep 2 - Dish Rinse Station	ACO11503	2019-10-20	<0.0005	Passed	0.0390	Passed	
Tamarac Education Centre	Food Prep 3 - Sink at Center Prep Station	ACO11504	2019-10-20	<0.0005	Passed	0.0200	Passed	
Tamarac Education Centre	Food Prep 4 - Left Wall in YSF	ACO11505	2019-10-20	<0.0005	Passed	0.0240	Passed	
Tamarac Education Centre	Food Prep 5 - Teachers Lounge	ACO11506	2019-10-20	<0.0005	Passed	0.0400	Passed	
Tamarac Education Centre	Food Prep 6 - First on Right Wall by Classroom Entrance	ACO11507	2019-10-20	<0.0005	Passed	0.0260	Passed	
Whycocomagh Education Centre	Fountain 1 - Washroom Across From Cafeteria	ACO11508	2019-11-02	<0.0005	Passed	0.4400	Passed	
Whycocomagh Education Centre	Fountain 2 - Outside Family Studies	ACO11509	2019-11-02	<0.0005	Passed	0.3900	Passed	

School Name	Location	Sample ID	Date	Lead (Pb) mg/L	Lead Result	Copper (Cu) mg/L	Copper Result	Remediation Plan
Whycocomagh Education Centre	Fountain 3 - Server Room 156	ACO11510	2019-11-02	<0.0005	Passed	0.2900	Passed	
Whycocomagh Education Centre	Food Prep 1 Cafeteria Kitchen Sink	ACO11511	2019-11-02	0.0008	Passed	0.4500	Passed	
Whycocomagh Education Centre	Food Prep 2 - Double Sink Next to Dishwasher	ACO11512	2019-11-02	0.0012	Passed	0.3900	Passed	
Whycocomagh Education Centre	Food Prep 3 - Day Care Small Sink	ACO11513	2019-11-02	<0.0005	Passed	0.3700	Passed	
Whycocomagh Education Centre	Food Prep 4 - Day Care Double Sink	ACO11514	2019-11-02	<0.0005	Passed	0.2800	Passed	
Whycocomagh Education Centre	Food Prep 5 - Family Studies Hall Side Double Sink	ACO11515	2019-11-02	0.0007	Passed	0.3200	Passed	
Whycocomagh Education Centre	Food Prep 6 - 1st Sink Island Door Side	WEC-PW20-001-KS1	2020-10-23	0.0011	Passed	0.3600	Passed	
Whycocomagh Education Centre	Food Prep 7 - Island Sink Window Side	ACO11517	2019-11-02	0.0044	Passed	0.3500	Passed	
Whycocomagh Education Centre	Food Prep 8 - Pre Primary	ACO11518	2019-11-02	0.0008	Passed	0.3700	Passed	
Whycocomagh Education Centre	Food Prep 9 - Wall Sink Window Side	ACO11519	2019-11-02	0.0014	Passed	0.3100	Passed	
Whycocomagh Education Centre	Food Prep 10 - Staff Room	ACO11520	2019-11-02	0.0007	Passed	0.3900	Passed	